

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
E31	GL03	03/08/2020	0.258	<0.02	0	0	0.281
	1015		0.131	<0.02	0	0	0.483
E32	G014	03/08/2020	0.388	<0.02	0	0	1.111
	1L03		0.235	<0.02	0	0	0.326
E33	G007	03/08/2020	0.195	<0.02	0	0	0.308
	1032		0.495	<0.02	0	0	0.309
	2038		0.779	<0.02	0	0	0.360
	3039		0.565	<0.02	0	0	0.349
W11	G036	10/08/2020	0.316	<0.02	0	0	0.288
	1019		0.172	<0.02	0	0	0.334
	1038		0.377	<0.02	0	0	0.872
	2022		0.677	<0.02	0	0	0.162
	2041		0.413	<0.02	0	0	0.154
	3022		0.551	<0.02	0	0	0.370
	3041		0.315	<0.02	0	0	0.607
	4022		0.404	<0.02	0	0	0.390
	4041		0.283	<0.02	0	0	0.776
	5022		1.990	<0.02	0	0	0.184
	5036		0.307	<0.02	0	0	0.246
	6018		0.191	<0.02	0	0	0.285
	6038		0.111	<0.02	0	0	0.129
	7003		0.736	<0.02	0	0	0.178

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
W12	1019	17/08/2020	0.619	<0.02	0	0	0.306
	1038		0.467	<0.02	0	0	0.283
	2022		0.783	<0.02	0	0	0.364
	2041		0.675	<0.02	0	0	0.335
	3021		0.498	<0.02	0	0	0.254
	3041		0.467	<0.02	0	0	0.252
	4022		0.388	<0.02	0	0	0.327
	4041		0.405	<0.02	0	0	0.286
	5022		0.560	<0.02	0	0	0.435
	6018		0.400	<0.02	0	0	0.300
	6032		0.265	<0.02	0	0	0.280
	7003		0.841	<0.02	0	0	0.329
W13	G036	24/08/2020	0.459	<0.02	0	0	0.339
	1019		0.169	<0.02	0	0	0.411
	1038		0.741	<0.02	0	0	0.200
	2041		0.221	<0.02	0	0	0.133
	3022		0.227	<0.02	0	0	1.085
	3041		0.152	<0.02	0	0	0.278
	4022		0.249	<0.02	0	0	0.208
	4041		0.275	<0.02	0	0	0.351
	5023		0.250	<0.02	0	0	0.409
	5036		0.838	<0.02	0	0	0.482
	6019		0.878	<0.02	0	0	0.718
	6032		0.333	<0.02	0	0	0.218
	7003		0.369	<0.02	0	0	0.230

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值

鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
W14	G035	31/08/2020	0.156	<0.02	0	0	0.237
	1021		1.350	<0.02	0	0	0.308
	1038		0.356	<0.02	0	0	0.419
	2023		0.216	<0.02	0	0	0.352
	2041		0.276	<0.02	0	0	0.285
	3023		0.321	<0.02	0	0	0.342
	3041		0.378	<0.02	0	0	0.568
	4023		0.405	<0.02	0	0	0.420
	4041		0.432	<0.02	0	0	1.049
	5023		0.386	<0.02	0	0	0.306
	5036		0.701	<0.02	0	0	0.423
	6018		0.399	<0.02	0	0	0.350
	6032		0.883	<0.02	0	0	0.524
	7003		0.510	<0.02	0	0	0.521

參考標準值: 澳門政府第46/96/M號法令<澳門供排水規章> 可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml