

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Coliform bacteria (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
W21	G019	07/09/2020	0.347	<0.02	0	0	0.214
	1020		0.163	<0.02	0	0	0.228
	1061		0.068	<0.02	0	0	0.194
	2025		0.134	<0.02	0	0	0.155
	2066		0.065	<0.02	0	0	0.143
	3001		0.067	<0.02	0	0	0.193
	4037		0.176	<0.02	0	0	0.200
	5001		0.176	<0.02	0	0	0.266
	5036		0.086	<0.02	0	0	0.252
	6014		0.211	<0.02	0	0	0.189
	7013		0.228	<0.02	0	0	0.283
W22	G020	14&21/09/2020	0.072	<0.02	0	0	0.239
	1020		0.051	<0.02	0	0	0.056
	1061		0.027	<0.02	0	0	0.203
	2025		0.165	<0.02	0	0	0.148
	2066		0.047	<0.02	0	0	0.145
	3025		0.063	<0.02	0	0	0.158
	3066		0.096	<0.02	0	0	0.171
	4001		0.097	<0.02	0	0	0.384
	4023		0.110	<0.02	0	0	0.092
	4059		0.226	<0.02	0	0	0.193
	5001		0.085	<0.02	0	0	0.240
	5039		0.130	<0.02	0	0	0.143
	6013		0.453	<0.02	0	0	0.441

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Coliform bacteria: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Coliform bacteria (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
W23	G009	21&28/09/2020	0.154	<0.02	0	0	0.206
	G033		0.157	<0.02	0	0	0.296
	1031		0.167	<0.02	0	0	0.389
	1052		0.094	<0.02	0	0	0.164
	2031		0.162	<0.02	0	0	0.264
	2056		0.100	<0.02	0	0	0.193
	3031		0.144	<0.02	0	0	0.197
	3056		0.149	<0.02	0	0	0.302
	4031		0.181	<0.02	0	0	0.196
	4056		0.200	<0.02	0	0	0.331
W33	G044	28/09/2020	0.208	<0.02	0	0	0.311
	1009		0.191	<0.02	0	0	0.342
	1036		0.370	<0.02	0	0	0.607
	2009		0.292	<0.02	0	0	0.486
	2036		0.242	<0.02	0	0	0.405
	3009		0.223	<0.02	0	0	0.379
	3036		0.436	<0.02	0	0	0.359
	4009		0.293	<0.02	0	0	0.391
	4036		0.220	<0.02	0	0	0.298
	5009		0.426	<0.02	0	0	0.460
	5036		0.193	<0.02	0	0	0.296
	6005		0.312	<0.02	0	0	0.457

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Coliform bacteria: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml