

飲水機水質測試結果

| 地點/大樓 | 位置 | 採樣日期 | 結果 | | | | |
|-------|------|------------|----------|----------|------------------|---------------------|----------|
| | | | 冷水 | | | | 熱水 |
| | | | 鉛 (µg/L) | 氯 (mg/L) | 大腸菌群 (mpn/100ml) | 埃希氏大腸桿菌 (mpn/100ml) | 鉛 (µg/L) |
| E31 | GL03 | 05/08/2019 | 0.165 | 0.02 | 0 | 0 | 0.211 |
| | 1015 | | 0.251 | <0.02 | 0 | 0 | 0.395 |
| E32 | G014 | 05/08/2019 | 0.124 | <0.02 | 0 | 0 | 0.218 |
| | 1L03 | | 0.350 | <0.02 | 0 | 0 | 0.368 |
| E33 | G007 | 05/08/2019 | 0.163 | <0.02 | 0 | 0 | 0.098 |
| | 1032 | | 0.089 | <0.02 | 0 | 0 | 0.102 |
| | 2038 | | 0.295 | <0.02 | 0 | 0 | 0.660 |
| | 3039 | | 0.179 | <0.02 | 0 | 0 | 1.077 |
| W11 | G036 | 12/08/2019 | 1.920 | <0.02 | 0 | 0 | 0.336 |
| | 1019 | | 1.115 | <0.02 | 0 | 0 | 0.370 |
| | 1038 | | 0.371 | <0.02 | 0 | 0 | 0.351 |
| | 2022 | | 0.482 | <0.02 | 0 | 0 | 0.263 |
| | 2041 | | 0.445 | <0.02 | 0 | 0 | 0.274 |
| | 3022 | | 0.511 | <0.02 | 0 | 0 | 0.295 |
| | 3041 | | 0.517 | <0.02 | 0 | 0 | 0.416 |
| | 4022 | | 0.498 | <0.02 | 0 | 0 | 0.394 |
| | 4041 | | 0.534 | <0.02 | 0 | 0 | 0.583 |
| | 5022 | | 0.379 | <0.02 | 0 | 0 | 0.286 |
| | 5036 | | 0.623 | 0.04 | 0 | 0 | 0.426 |
| | 6018 | | 0.357 | <0.02 | 0 | 0 | 0.243 |
| | 6032 | | 0.405 | <0.02 | 0 | 0 | 0.268 |
| | 7003 | | 0.465 | <0.02 | 0 | 0 | 0.313 |

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

| 地點/大樓 | 位置 | 採樣日期 | 結果 | | | | |
|-------|-------|------------|----------|----------|------------------|---------------------|----------|
| | | | 冷水 | | | | 熱水 |
| | | | 鉛 (µg/L) | 氯 (mg/L) | 大腸菌群 (mpn/100ml) | 埃希氏大腸桿菌 (mpn/100ml) | 鉛 (µg/L) |
| W12 | G037 | 19/08/2019 | 0.110 | <0.02 | 0 | 0 | 0.110 |
| | 1019 | | 0.351 | <0.02 | 0 | 0 | 0.345 |
| | 1038 | | 0.324 | <0.02 | 0 | 0 | 0.339 |
| | 2041 | | 0.081 | <0.02 | 0 | 0 | 0.192 |
| | 3022 | | 0.152 | <0.02 | 0 | 0 | 0.270 |
| | 3041 | | 0.624 | <0.02 | 0 | 0 | 0.152 |
| | 4022 | | 0.176 | <0.02 | 0 | 0 | 0.308 |
| | 4041 | | 0.151 | <0.02 | 0 | 0 | 0.277 |
| | 5022 | | 0.288 | <0.02 | 0 | 0 | 0.313 |
| | 5036 | | 0.157 | <0.02 | 0 | 0 | 0.164 |
| | 6018 | | 0.225 | <0.02 | 0 | 0 | 0.304 |
| | 7003 | | 0.345 | <0.02 | 0 | 0 | 0.225 |
| W13 | G036 | 26/08/2019 | 0.063 | <0.02 | 0 | 0 | 0.167 |
| | 1019 | | 0.149 | <0.02 | 0 | 0 | 0.304 |
| | 1038 | | 0.485 | <0.02 | 0 | 0 | 0.245 |
| | 2022 | | 0.101 | <0.02 | 0 | 0 | 0.198 |
| | 2041 | | 0.238 | <0.02 | 0 | 0 | 0.290 |
| | 3022 | | 0.172 | <0.02 | 0 | 0 | 0.416 |
| | 3041 | | 0.134 | <0.02 | 0 | 0 | 0.260 |
| | 4022 | | 0.155 | <0.02 | 0 | 0 | 0.211 |
| | 4041 | | 0.124 | <0.02 | 0 | 0 | 0.229 |
| | 5022 | | 0.528 | <0.02 | 0 | 0 | 0.395 |
| | 5036 | | 0.243 | <0.02 | 0 | 0 | 0.278 |
| | 6018 | | 0.123 | <0.02 | 0 | 0 | 0.278 |
| | 6032 | | 0.602 | <0.02 | 0 | 0 | 0.425 |
| 7003 | 0.233 | <0.02 | 0 | 0 | 0.517 | | |

參考標準值: 澳門政府第46/96/M號法令 <澳門供排水規章> 可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml