

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
E31	GL03	05/08/2019	0.165	0.02	0	0	0.211
	1015		0.251	<0.02	0	0	0.395
E32	G014	05/08/2019	0.124	<0.02	0	0	0.218
	1L03		0.350	<0.02	0	0	0.368
E33	G007	05/08/2019	0.163	<0.02	0	0	0.098
	1032		0.089	<0.02	0	0	0.102
	2038		0.295	<0.02	0	0	0.660
	3039		0.179	<0.02	0	0	1.077
W11	G036	12/08/2019	1.920	<0.02	0	0	0.336
	1019		1.115	<0.02	0	0	0.370
	1038		0.371	<0.02	0	0	0.351
	2022		0.482	<0.02	0	0	0.263
	2041		0.445	<0.02	0	0	0.274
	3022		0.511	<0.02	0	0	0.295
	3041		0.517	<0.02	0	0	0.416
	4022		0.498	<0.02	0	0	0.394
	4041		0.534	<0.02	0	0	0.583
	5022		0.379	<0.02	0	0	0.286
	5036		0.623	0.04	0	0	0.426
	6018		0.357	<0.02	0	0	0.243
	6032		0.405	<0.02	0	0	0.268
	7003		0.465	<0.02	0	0	0.313

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
W12	G037	19/08/2019	0.110	<0.02	0	0	0.110
	1019		0.351	<0.02	0	0	0.345
	1038		0.324	<0.02	0	0	0.339
	2041		0.081	<0.02	0	0	0.192
	3022		0.152	<0.02	0	0	0.270
	3041		0.624	<0.02	0	0	0.152
	4022		0.176	<0.02	0	0	0.308
	4041		0.151	<0.02	0	0	0.277
	5022		0.288	<0.02	0	0	0.313
	5036		0.157	<0.02	0	0	0.164
	6018		0.225	<0.02	0	0	0.304
	7003		0.345	<0.02	0	0	0.225
W13	G036	26/08/2019	0.063	<0.02	0	0	0.167
	1019		0.149	<0.02	0	0	0.304
	1038		0.485	<0.02	0	0	0.245
	2022		0.101	<0.02	0	0	0.198
	2041		0.238	<0.02	0	0	0.290
	3022		0.172	<0.02	0	0	0.416
	3041		0.134	<0.02	0	0	0.260
	4022		0.155	<0.02	0	0	0.211
	4041		0.124	<0.02	0	0	0.229
	5022		0.528	<0.02	0	0	0.395
	5036		0.243	<0.02	0	0	0.278
	6018		0.123	<0.02	0	0	0.278
	6032		0.602	<0.02	0	0	0.425
7003	0.233	<0.02	0	0	0.517		

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml