

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
E2	G003	08/07/2019	0.088	<0.02	0	0	0.035
	G029		0.620	<0.02	0	0	0.258
	1004		0.116	<0.02	0	0	0.066
	1040		0.671	<0.02	0	0	0.039
	2004		0.063	<0.02	0	0	< 0.028
	2045		0.033	<0.02	0	0	< 0.028
	3005		< 0.028	<0.02	0	0	< 0.028
	3033		< 0.028	<0.02	0	0	< 0.028
	4005		0.037	<0.02	0	0	< 0.028
	4033		< 0.028	<0.02	0	0	< 0.028
E3	GL07	15/07/2019	0.269	<0.02	0	0	< 0.023
	1L07		0.118	<0.02	0	0	0.239
	2L07		0.443	<0.02	0	0	0.211
	3L07		0.044	<0.02	0	0	0.250
	4L05		< 0.023	<0.02	0	0	0.032
E4	GL09	15/07/2019	0.158	<0.02	0	0	0.299
	1L09		0.207	<0.02	0	0	0.276
	3L10		< 0.023	<0.02	0	0	0.309
E5	GL12	15/07/2019	0.538	<0.02	0	0	0.023
	1L11		0.327	<0.02	0	0	0.287
E6	GL15	15/07/2019	0.058	<0.02	0	0	0.152
	GL18		< 0.023	<0.02	0	0	0.532
	1L18		< 0.023	<0.02	0	0	< 0.023
	2L18		0.532	<0.02	0	0	0.158
	3L15		0.583	<0.02	0	0	0.239

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau

Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; E.coli count: 0 mpn/100ml

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
E11	GL04	22/07/2019	0.466	<0.02	0	0	0.122
	1L04		0.774	0.03	0	0	0.150
	1J02		0.215	<0.02	0	0	0.122
	2L04		0.265	<0.02	0	0	0.248
	2L08		0.526	<0.02	0	0	0.075
	3L04		0.152	<0.02	0	0	0.125
	3091		0.164	<0.02	0	0	0.114
E12	GL05	22/07/2019	0.053	<0.02	0	0	0.049
	1058		0.099	<0.02	0	0	0.403
	1L01		0.182	<0.02	0	0	0.269
	2081		0.296	<0.02	0	0	0.282
	3086		0.173	<0.02	0	0	0.257
E21	G004	29/07/2019	0.041	<0.02	0	0	0.170
	G045		0.100	<0.02	0	0	0.178
	1005		0.052	<0.02	0	0	0.152
	1028		0.741	<0.02	0	0	0.229
	1051		0.025	<0.02	0	0	0.154
	2009		0.096	<0.02	0	0	0.072
	3101		0.238	<0.02	0	0	0.126
E22	1L05	29/07/2019	0.042	<0.02	0	0	0.393
	2L05		0.770	<0.02	0	0	0.111
	3L05		0.612	<0.02	0	0	0.380
	4L05		1.009	<0.02	0	0	0.189

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml