

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果							
			冷水					熱水		
			渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)
S3	C1-1040	05/09/2022	0.11	7.41	0.219	0	0	0	7.41	0.472
	C1-2040		0.07	7.42	0.222	0	0	0.07	7.66	0.455
	C1-3040		0.13	7.50	0.134	0	0	0.08	7.67	0.204
	C1-4040		0.10	7.62	0.085	0	0	0.06	7.72	0.142
	C1-5040		0.19	7.34	0.390	0	0	0.10	7.50	0.651
	C1-6040		0.09	7.41	0.171	0	0	0.05	7.62	0.334
	C1-7040		0.13	7.29	0.288	0	0	0.06	7.47	0.392
	C1-8040		0.10	7.50	0.140	0	0	0.07	7.71	0.224
	C1-9012		0.09	7.35	0.272	0	0	0.06	7.54	0.324
	C2-1009		0.17	7.27	0.323	0	0	0.12	7.48	1.016
	C2-2009		0.06	7.63	0.056	0	0	0.05	7.62	0.076
	C2-3009		0.12	7.45	0.206	0	0	0.06	7.54	0.230
	C2-4009		0.11	7.33	0.231	0	0	0.07	7.50	0.385
	C2-5009		0.13	7.46	0.150	0	0	0.09	7.57	0.277
	C2-6009		0.13	7.47	0.304	0	0	0.09	7.53	0.474
	C2-7009		0.08	7.47	0.073	0	0	0.07	7.76	1.291
	C2-8009		0.07	7.62	0.176	0	0	0.07	7.76	0.281
	C3-1052		0.07	7.43	0.193	0	0	0.06	7.60	0.249
	C3-2060		0.06	7.67	0.109	0	0	0.05	7.80	0.168
	C3-3060		0.08	7.39	0.292	0	0	0.07	7.55	0.480
	C3-4060		0.07	7.44	0.090	0	0	0.06	7.47	0.126
C3-5060	0.09	7.37	0.212	0	0	0.07	7.55	0.344		
C3-6060	0.08	7.61	0.115	0	0	0.07	7.70	0.265		
C3-7060	0.08	7.62	0.127	0	0	0.07	7.76	0.217		
C3-8060	0.16	7.41	0.383	0	0	0.09	7.73	0.460		

參考標準: 澳門特別行政區政府環境保護局選擇和設置直飲式水機的指引
 渾濁度: =<0.5NTU; 酸鹼值: 6.00-8.5; 微量金屬鉛: =<10µg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果							
			冷水					熱水		
			渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)
S4	1001	13/09/2022	0.05	7.88	<0.07	0	0	0.08	7.71	0.105
	2001		0.04	7.84	<0.07	0	0	0.07	7.80	<0.07
	3001		0.06	7.73	<0.07	0	0	0.06	7.73	<0.07
	4001		0.06	7.72	<0.07	0	0	0.05	7.73	<0.07
	5001		0.10	7.60	<0.07	0	0	0.09	7.74	0.129
	6001		0.08	7.72	<0.07	0	0	0.08	7.73	<0.07
	7001		0.06	7.57	<0.07	0	0	0.07	7.75	0.079
	8001		0.06	7.61	<0.07	0	0	0.07	7.87	<0.07
	9001		0.06	7.60	<0.07	0	0	0.07	7.72	0.175
	10001		0.05	7.67	<0.07	0	0	0.06	7.69	0.104
W31	G043	19/09/2022	0.07	7.84	0.063	0	0	0.06	7.75	0.074
	G053		0.04	7.81	0.074	0	0	0.04	7.65	0.021
	1019		0.04	8.02	0.035	0	0	0.04	7.87	0.048
	2019		0.05	7.98	0.026	0	0	0.05	7.88	0.042
	2063		0.06	8.00	0.056	0	0	0.04	7.97	0.024
	3019		0.07	7.87	0.019	0	0	0.06	7.83	0.033
	3063		0.05	7.95	0.019	0	0	0.06	7.95	0.007
	4019		0.10	7.81	0.021	0	0	0.07	7.76	0.043
	4063		0.04	7.99	0.022	0	0	0.04	7.94	0.014
	5019		0.05	7.82	0.046	0	0	0.08	7.74	0.078
	5063		0.04	8.16	0.009	0	0	0.04	8.04	0.006
	6019		0.05	8.13	0.033	0	0	0.04	7.94	0.035
	6063		0.05	8.10	0.037	0	0	0.04	7.94	0.089
	7019		0.05	8.09	0.062	0	0	0.04	7.71	0.101

參考標準: 澳門特別行政區政府環境保護局選擇和設置直飲式水機的指引

渾濁度: =<0.5NTU; 酸鹼值: 6.00-8.5; 微量金屬鉛: =<10µg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果							
			冷水					熱水		
			渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	渾濁度 (NTU)	酸鹼值	微量金屬鉛 (µg/L)
W32	G015	19/09/2022	0.05	7.75	0.040	0	0	0.06	7.73	0.076
	G042		0.06	7.67	0.035	0	0	0.06	7.72	0.007
	1023		0.06	7.77	0.040	0	0	0.07	7.64	0.067
	1053		0.05	7.78	0.021	0	0	0.05	7.66	0.091
	2023		0.07	7.73	0.065	0	0	0.06	7.71	0.043
	2053		0.10	7.87	0.069	0	0	0.05	7.80	0.239
	3023		0.07	7.68	0.028	0	0	0.06	7.75	0.047
	3053		0.07	7.74	0.021	0	0	0.05	7.74	0.056
	4023		0.07	7.68	0.038	0	0	0.05	7.58	0.055
	4053		0.13	7.68	0.061	0	0	0.06	7.68	0.054
	5023		0.06	7.63	0.032	0	0	0.08	7.66	0.113
	5053		0.06	7.61	0.034	0	0	0.08	7.70	0.149
	6023		0.12	7.61	0.038	0	0	0.06	7.68	0.080
	6053		0.06	7.62	0.026	0	0	0.08	7.61	0.120
	7013		0.08	7.66	0.109	0	0	0.08	7.71	0.194
W13	G036	26/09/2022	0.06	7.86	0.084	0	0	0.06	7.68	0.385
	1021		0.04	7.71	<0.07	0	0	0.04	7.67	0.131
	1038		0.06	7.61	<0.07	0	0	0.07	7.58	<0.07
	2023		0.08	7.66	<0.07	0	0	0.05	7.67	0.130
	2041		0.05	7.56	<0.07	0	0	0.05	7.70	0.280
	3023		0.05	7.72	<0.07	0	0	0.05	7.80	0.354
	3041		0.06	7.75	<0.07	0	0	0.04	7.76	0.137
	4023		0.06	7.65	<0.07	0	0	0.10	7.62	<0.07
	4041		0.05	7.73	<0.07	0	0	0.05	7.75	0.114
	5023		0.05	7.63	<0.07	0	0	0.07	7.64	<0.07
	5036		0.04	7.65	<0.07	0	0	0.05	7.70	0.132
	6019		0.05	7.64	0.101	0	0	0.07	7.83	0.195
	6032		0.05	7.66	<0.07	0	0	0.04	7.67	0.204
	7003		0.09	7.51	<0.07	0	0	0.05	7.61	0.136

參考標準: 澳門特別行政區政府環境保護局選擇和設置直飲式水機的指引

渾濁度: <0.5NTU; 酸鹼值: 6.00-8.5; 微量金屬鉛: <10µg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml