

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
W12	G037	09/03/2020	0.939	<0.02	0	0	1.673
	1019		1.814	<0.02	0	0	0.314
	1038		0.106	<0.02	0	0	0.563
	2022		1.744	<0.02	0	0	1.319
	2041		0.774	<0.02	0	0	0.522
	3022		0.270	<0.02	0	0	0.250
	3041		0.852	<0.02	0	0	1.479
	4022		0.167	<0.02	0	0	0.863
	4041		0.646	<0.02	0	0	0.492
	5022		1.037	<0.02	0	0	0.461
	5036		0.890	<0.02	0	0	1.007
	6018		0.725	<0.02	0	0	<0.005
	6032		0.996	<0.02	0	0	0.977
	7003		0.409	<0.02	0	0	0.424
W14	G008	09/03/2020	0.144	<0.02	0	0	0.357
	1021		0.385	<0.02	0	0	0.227
	1038		1.130	<0.02	0	0	0.357
	2023		0.633	<0.02	0	0	0.178
	2041		0.185	<0.02	0	0	0.230
	3023		0.153	<0.02	0	0	0.848
	3041		0.493	<0.02	0	0	0.364
	4023		2.432	<0.02	0	0	0.393
	4041		0.444	<0.02	0	0	0.450
	5023		0.285	<0.02	0	0	0.551
	5036		2.469	<0.02	0	0	0.147
	6019		0.246	<0.02	0	0	0.118
	6032		4.890	<0.02	0	0	1.370
	7003		2.235	<0.02	0	0	1.273

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
W21	G019	17/03/2020	0.340	<0.02	0	0	0.176
	1020		0.345	<0.02	0	0	0.279
	1061		0.197	<0.02	0	0	0.176
	2025		0.232	<0.02	0	0	0.224
	2066		0.232	<0.02	0	0	0.286
	3001		0.225	<0.02	0	0	0.291
	3023		0.371	<0.02	0	0	0.178
	3066		0.267	<0.02	0	0	0.152
	4001		0.363	<0.02	0	0	0.178
	4037		0.192	<0.02	0	0	0.138
	5001		0.337	<0.02	0	0	0.162
	5036		0.319	<0.02	0	0	0.191
	6014		0.636	<0.02	0	0	0.628
	7013		0.230	<0.02	0	0	0.165
W22	1020	24/03/2020	0.317	<0.02	0	0	0.412
	1061		0.240	<0.02	0	0	0.321
	2025		1.591	<0.02	0	0	0.271
	2066		0.273	<0.02	0	0	0.415
	3025		0.955	<0.02	0	0	0.308
	3066		0.869	<0.02	0	0	2.510
	4001		0.373	<0.02	0	0	1.257
	4023		0.585	<0.02	0	0	0.444
	4059		0.469	<0.02	0	0	0.284
	5001		1.941	<0.02	0	0	0.313
	5039		0.440	<0.02	0	0	0.358
6013	1.121	<0.02	0	0	0.251		

參考標準值: 澳門政府第46/96/M號法令 <澳門供排水規章> 可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
E31	GL03	31/03/2020	0.065	<0.02	0	0	0.167
	1015		1.631	<0.02	0	0	0.172
E32	G014	31/03/2020	0.099	<0.02	0	0	0.327
	1L03		0.078	<0.02	0	0	0.235
E33	G007	31/03/2020	0.055	<0.02	0	0	0.085
	1032		1.364	<0.02	0	0	0.622
	2038		0.336	<0.02	0	0	0.463
	3039		0.467	<0.02	0	0	0.463
W23	G009	31/03/2020	0.062	<0.02	0	0	0.148
	G033		0.018	<0.02	0	0	0.042
	1031		0.985	<0.02	0	0	0.248
	1052		0.422	<0.02	0	0	0.169
	2031		0.508	<0.02	0	0	0.108
	2056		0.637	<0.02	0	0	0.087
	3031		1.181	<0.02	0	0	0.566
	3056		0.250	<0.02	0	0	0.289
	4031		0.426	<0.02	0	0	0.100
	4056		0.426	<0.02	0	0	0.193

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml