

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
S3	C1-1040	03&10/06/2019	0.108	<0.02	0	0	0.188
	C1-2040		0.163	<0.02	0	0	0.206
	C1-3040		0.140	<0.02	0	0	0.237
	C1-4040		<0.003	<0.02	0	0	0.212
	C1-5040		0.366	<0.02	0	0	0.837
	C1-6040		0.197	<0.02	0	0	0.298
	C1-7040		0.457	<0.02	0	0	0.451
	C1-8040		0.474	<0.02	0	0	0.278
	C1-9012		0.212	<0.02	0	0	0.266
	C2-1009		0.272	<0.02	0	0	0.265
	C2-2009		0.252	<0.02	0	0	0.255
	C2-3009		0.326	<0.02	0	0	0.287
	C2-4009		0.163	<0.02	0	0	0.315
	C2-5009		0.239	<0.02	0	0	0.254
	C2-6009		0.135	<0.02	0	0	0.147
	C2-7009		0.086	<0.02	0	0	0.170
	C2-8009		0.095	<0.02	0	0	0.182
	C3-1052		0.172	<0.02	0	0	0.219
	C3-2060		0.169	<0.02	0	0	0.195
	C3-3060		0.161	<0.02	0	0	0.402
	C3-4060		0.084	<0.02	0	0	0.251
	C3-5060		0.122	<0.02	0	0	0.214
	C3-6060		0.130	<0.02	0	0	0.244
	C3-7060		0.188	<0.02	0	0	0.308
C3-8060	0.218	<0.02	0	0	0.367		

參考標準值: 澳門政府第46/96/M號法令 <澳門供排水規章> 可接受最大值

鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
S4	1001	10/06/2019	0.377	<0.02	0	0	0.170
	2001		0.160	<0.02	0	0	0.142
	3001		0.347	<0.02	0	0	0.209
	4001		0.331	<0.02	0	0	0.238
	5001		0.159	<0.02	0	0	0.331
	6001		0.089	<0.02	0	0	0.314
	7001		0.111	<0.02	0	0	0.224
	8001		0.078	<0.02	0	0	0.220
	9001		0.123	<0.02	0	0	0.164
	10001		0.113	<0.02	0	0	0.148

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml