

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
N8	GL01	07/05/2019	0.031	<0.02	0	0	0.025
	GL11		0.045	<0.02	0	0	0.112
	GL12		0.087	<0.02	0	0	0.276
	1L01		0.079	<0.02	0	0	0.405
	3006		0.081	<0.02	0	0	0.209
	3L02		0.035	<0.02	0	0	0.089
	4009		0.419	<0.02	0	0	0.509
N21	2016	14/05/2019	0.057	<0.02	0	0	0.061
	3016		0.037	<0.02	0	0	0.061
N22	1049	20/05/2019	0.357	<0.02	0	0	0.720
	2016		0.191	<0.02	0	0	0.358
	3020		0.025	<0.02	0	0	0.151
	4015		0.106	<0.02	0	0	0.286
	5011		0.086	<0.02	0	0	0.325
	8017		0.191	<0.02	0	0	0.553

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; E.coli count: 0 mpn/100ml

## Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
S1	1018	27/05/2019	0.046	<0.02	0	0	0.158
	2018		0.111	<0.02	0	0	0.098
	3018		0.124	<0.02	0	0	0.145
	4018		0.135	<0.02	0	0	0.112
	5018		0.178	<0.02	0	0	0.201
	6018		0.243	<0.02	0	0	0.294
	7018		1.003	<0.02	0	0	0.972
	8018		0.588	<0.02	0	0	0.107
S2	1001	27/05/2019	0.099	<0.02	0	0	0.044
	2001		0.109	<0.02	0	0	0.122
	3001		0.111	<0.02	0	0	0.071
	4001		0.056	<0.02	0	0	0.105
	5001		0.032	<0.02	0	0	0.086
	6001		0.081	<0.02	0	0	0.108
	7001		0.096	<0.02	0	0	0.140
	8001		0.055	<0.02	0	0	0.092
	9001		0.056	<0.02	0	0	0.129

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau  
Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; E.coli count: 0 mpn/100ml