

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
E21	G004	07/04/2020	0.191	<0.02	0	0	0.331
	G045		0.200	<0.02	0	0	0.244
	1005		0.215	<0.02	0	0	0.166
	1028		11.725	<0.02	0	0	0.378
	1051		0.159	<0.02	0	0	0.172
	2009		0.679	<0.02	0	0	0.518
	3L01		0.200	<0.02	0	0	0.157
E22	GL05	07/04/2020	0.099	<0.02	0	0	0.092
	1L04		0.123	<0.02	0	0	0.218
	2L05		0.280	<0.02	0	0	0.168
	3L05		1.007	<0.02	0	0	0.164
	4L05		1.641	<0.02	0	0	0.175
W33	G044	07/04/2020	0.974	<0.02	0	0	N/A
	1009		3.080	<0.02	0	0	0.517
	1036		2.339	<0.02	0	0	0.301
	2009		1.361	<0.02	0	0	0.202
	2036		0.471	<0.02	0	0	0.177
	3009		0.216	<0.02	0	0	0.220
	3036		1.401	<0.02	0	0	0.238
	4009		0.127	<0.02	0	0	0.295
	4036		0.299	<0.02	0	0	0.229
	5009		1.261	<0.02	0	0	0.982
	5036		0.209	<0.02	0	0	0.161
	6005		0.548	<0.02	0	0	0.329

參考標準值: 澳門政府第46/96/M號法令<澳門供排水規章> 可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
W34	G022	14/04/2020	0.431	<0.02	0	0	0.974
	1019		0.727	<0.02	0	0	0.652
	1046		0.420	<0.02	0	0	0.418
	2019		0.420	<0.02	0	0	0.357
	2046		0.364	<0.02	0	0	0.646
	3019		0.827	<0.02	0	0	0.349
	3046		1.290	<0.02	0	0	0.301
	4019		7.549	<0.02	0	0	0.629
	4046		1.057	<0.02	0	0	0.407
	5019		0.690	<0.02	0	0	0.538
	5046		0.393	<0.02	0	0	0.322
	6019		2.910	<0.02	0	0	0.312
	7019		2.888	<0.02	0	0	0.649
W11	G036	21/04/2020	0.583	<0.02	0	0	0.618
	1019		1.381	<0.02	0	0	0.718
	1038		0.599	<0.02	0	0	0.589
	2022		0.633	<0.02	0	0	0.429
	2041		1.258	<0.02	0	0	0.398
	3022		0.335	<0.02	0	0	0.305
	3041		1.487	<0.02	0	0	0.887
	4022		0.857	<0.02	0	0	0.455
	4041		1.133	<0.02	0	0	1.086
	5022		0.774	<0.02	0	0	0.383
	5036		1.505	<0.02	0	0	0.682
	6018		0.730	<0.02	0	0	0.411
	6032		0.388	<0.02	0	0	0.311
7003	0.904	<0.02	0	0	0.499		

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml

飲水機水質測試結果

地點/大樓	位置	採樣日期	結果				
			冷水				熱水
			鉛 (µg/L)	氯 (mg/L)	大腸菌群 (mpn/100ml)	埃希氏大腸桿菌 (mpn/100ml)	鉛 (µg/L)
S9	G008	27/04/2020	0.138	<0.02	0	0	0.171
	G010		0.054	<0.02	0	0	0.078
	1002		0.230	<0.02	0	0	0.224
	1033		0.570	<0.02	0	0	0.169
	2003		0.522	<0.02	0	0	0.604
	2038		2.612	<0.02	0	0	0.130
	3002		0.755	<0.02	0	0	0.907
	3038		1.389	<0.02	0	0	0.129
	4003		0.247	<0.02	0	0	0.344
	4038		0.656	<0.02	0	0	0.371
	5003		0.251	<0.02	0	0	0.151
	5038		5.307	<0.02	0	0	1.753
	6003		0.985	<0.02	0	0	0.801
	6038		2.559	<0.02	0	0	0.912
	7002		0.577	<0.02	0	0	0.196
7028	0.610	<0.02	0	0	0.390		
W13	G036	27/04/2020	1.785	<0.02	0	0	0.491
	1021		0.306	<0.02	0	0	0.186
	1038		2.379	<0.02	0	0	0.172
	2023		0.326	<0.02	0	0	0.201
	2041		0.733	<0.02	0	0	0.527
	3023		0.476	<0.02	0	0	0.685
	3041		0.659	<0.02	0	0	0.276
	4023		0.536	<0.02	0	0	0.148
	4041		0.579	<0.02	0	0	0.569
	5023		0.454	<0.02	0	0	0.505
	5036		0.404	<0.02	0	0	0.397
	6019		3.490	<0.02	0	0	1.320
	6032		0.329	<0.02	0	0	0.247
	7003		0.294	<0.02	0	0	0.388

參考標準值: 澳門政府第46/96/M號法令〈澳門供排水規章〉可接受最大值
 鉛: <0.05mg/L (<50µg/L); 氯: <0.5mg/L; 大腸菌群: 0 mpn/100ml; 埃希氏大腸桿菌: 0 mpn/100ml