

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
N8	GL01	05/11/2019	0.053	<0.02	0	0	0.069
	GL11		0.046	<0.02	0	0	0.100
	GL12		0.200	<0.02	0	0	0.233
	1L01		0.283	<0.02	0	0	0.364
	3006		0.011	<0.02	0	0	0.077
	3L02		0.204	<0.02	0	0	0.196
	4009		0.358	<0.02	0	0	0.406
N21	1017	12/11/2019	0.070	<0.02	0	0	0.142
	2016		0.146	<0.02	0	0	0.289
	3016		0.039	<0.02	0	0	0.085
N22	1053	19/11/2019	0.026	<0.02	0	0	0.191
	2061		0.031	<0.02	0	0	0.047
	3020		0.040	<0.02	0	0	0.041
	4015		0.052	<0.02	0	0	0.037
	5011		0.034	<0.02	0	0	0.042
	6016		0.032	<0.02	0	0	0.042
	7019		0.030	<0.02	0	0	0.038
	8017		0.033	<0.02	0	0	0.040

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau
Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml

Water Quality Test Result of Drinking Water Fountain

Building	Location	Sampling Date	Results				
			Cold water				Hot water
			Lead (µg/L)	Chlorine (mg/L)	Total coliform count (mpn/100ml)	<i>E.coli</i> count (mpn/100ml)	Lead (µg/L)
S1	1018	26/11/2019	0.124	<0.02	0	0	0.346
	2018		0.105	<0.02	0	0	0.122
	3018		0.297	<0.02	0	0	0.297
	4018		0.048	<0.02	0	0	0.078
	5018		0.129	<0.02	0	0	0.138
	6018		0.208	<0.02	0	0	0.256
	7018		0.821	<0.02	0	0	0.486
	8018		0.519	<0.02	0	0	0.404
S2	1001	26/11/2019	0.105	<0.02	0	0	0.087
	2001		0.076	<0.02	0	0	0.090
	3001		0.040	<0.02	0	0	0.060
	4001		0.081	<0.02	0	0	0.055
	5001		0.034	<0.02	0	0	0.094
	6001		0.056	<0.02	0	0	0.182
	7001		0.167	<0.02	0	0	0.144
	8001		0.094	<0.02	0	0	0.110
	9001		0.036	<0.02	0	0	0.067

Reference standard: VMA from Decreto-Lei n.º 46/96/M, Aprova o Regulamento de Águas e de Drenagem de Águas Residuais de Macau
 Lead: <0.05mg/L(<50µg/L); Chlorine: <0.5mg/L; Total coliform count: 0 mpn/100ml; *E.coli* count: 0 mpn/100ml